

Line Extension Analysis Requirements:**Summary:**

Due to New Mexico Public Utility Commission Case Number 2476, electric utilities in the state are required to provide information on alternative energy systems to remote customers with less than a 25-kW load who request line extensions. This requirement applies when the cost of the requested line extension is greater than 15 times the estimated annual revenue from the line extension. In such cases, utilities must provide customers with information on suppliers of alternative energy systems.

Contact:**John Curl**

New Mexico Public Regulation Commission
224 East Palace Ave.

Marian Hall

Santa Fe, NM 87501

Phone: (505) 827-6960

E-Mail: john.curl@state.nm.us

Web site: <http://www.nmprc.state.nm.us/>